

Proj. No. \_\_\_\_\_ DM \_\_\_\_\_ MM \_\_\_\_\_

CL-42 (MOR) rev 11/27/00

# IW MORGAN WATER APPLICATION FOR PLUMBING PERMIT

**IMPORTANT** Read instructions  
on reverse side carefully

I hereby apply for a 90-Day plumbing permit to perform the following described work in accordance with requirements of USFilter Indianapolis Water, LLC. and as instructed on the reverse side of this application.

Plumbing Company That Will Install Service \_\_\_\_\_

**SERVICE LOCATION INFORMATION**

House No. \_\_\_\_\_ Street Name \_\_\_\_\_ Apt. No. \_\_\_\_\_ City \_\_\_\_\_ County \_\_\_\_\_

Subdivision \_\_\_\_\_ Lot No. \_\_\_\_\_ Zip Code \_\_\_\_\_ Township \_\_\_\_\_

**DOMESTIC OR IRRIGATION INFORMATION**

**BUILDING TYPE:** Existing \_\_\_\_\_ New \_\_\_\_\_

**CUSTOMER TYPE:** Residential \_\_\_\_\_ Industrial \_\_\_\_\_ Multi-Family \_\_\_\_\_  
 Condominium \_\_\_\_\_ Other Util \_\_\_\_\_ Irrigation \_\_\_\_\_  
 Commercial \_\_\_\_\_ None of the above \_\_\_\_\_

**METER LOCATION:** Pit \_\_\_\_\_ Multi-Mtr in Pit \_\_\_\_\_  
 Inside \_\_\_\_\_  
 Existing Services to be killed: Yes \_\_\_\_\_ No \_\_\_\_\_

Reason for new service:  
 Without Water \_\_\_\_\_ Electric Pump \_\_\_\_\_  
 Hand Pump \_\_\_\_\_ Another Service \_\_\_\_\_  
 Inadequate Service \_\_\_\_\_

**TYPE OF SERVICE LINE:** New \_\_\_\_\_ Extend Dead End \_\_\_\_\_  
 Branch of New \_\_\_\_\_ Other \_\_\_\_\_ Replacement of \_\_\_\_\_  
 Branch of Existing: \_\_\_\_\_ Existing \_\_\_\_\_

**SIZES & QUANTITY REQUIREMENTS:** Service Line Diameter \_\_\_\_\_  
 No. of Meters \_\_\_\_\_ Size \_\_\_\_\_

**SPECIAL REQUIREMENTS:** Backflow Prevention \_\_\_\_\_  
 Yes \_\_\_\_\_ No \_\_\_\_\_

Address \_\_\_\_\_ Attachment No. \_\_\_\_\_

**OTHER SUPPLY:** Yes \_\_\_\_\_ No \_\_\_\_\_

**TYPE:** Primary \_\_\_\_\_ Cooling \_\_\_\_\_  
 Secondary \_\_\_\_\_ Other \_\_\_\_\_  
 No. of Wells \_\_\_\_\_

Location of Water Main \_\_\_\_\_ Size Main \_\_\_\_\_  
 Street Name \_\_\_\_\_

**FIRE LINE INFORMATION**

New \_\_\_\_\_ Existing \_\_\_\_\_ Comments: \_\_\_\_\_ Location of Water Main \_\_\_\_\_ Size Main \_\_\_\_\_  
 (Street Name)

Fire Service District/Township \_\_\_\_\_ Freeze prevention used \_\_\_\_\_ Domestic service from \_\_\_\_\_ Address \_\_\_\_\_

**TYPE OF FIRE PROTECTION TO BE INSTALLED:** Hydrants only \_\_\_\_\_ Hydrant and Sprinkler Systems \_\_\_\_\_ Fire Meter and Hydrants \_\_\_\_\_ No. of Hydrants \_\_\_\_\_ Requested: \_\_\_\_\_ GPM at \_\_\_\_\_ PSI  
 Sprinkler Systems \_\_\_\_\_ and/or Hose Cabinets \_\_\_\_\_ Fire Meter w/hydrant, \_\_\_\_\_ Size Line \_\_\_\_\_ at USFIW Main.  
 and/or Hose Cabinets \_\_\_\_\_ Fire Meter \_\_\_\_\_ sprinklers and/or hose cabinet \_\_\_\_\_

**SYSTEM COMPONENTS TO BE INSTALLED:** Booster Pump \_\_\_\_\_ Check Valves \_\_\_\_\_ Ground Reservoir Volume in gallons \_\_\_\_\_ Approved for: \_\_\_\_\_ GPM at \_\_\_\_\_ PSI  
 Jockey Pump & \_\_\_\_\_ in Main Line \_\_\_\_\_ Elevated Reservoir Volume in gallons \_\_\_\_\_ at USFIW Main.  
 Meter Size \_\_\_\_\_ " \_\_\_\_\_ in Riser \_\_\_\_\_ Backflow Preventor \_\_\_\_\_

**PLUMBER:**  
 Plumbing Company That Will Install Service \_\_\_\_\_ Date \_\_\_\_\_  
 Plumber's Signature \_\_\_\_\_ Tel # \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_

**OWNER/CONTRACTOR:**  
 I, the undersigned, authorize the above-named plumber to perform the work described in this application in accordance with the regulations on the reverse side of this application. I accept responsibility for paying the water bill when the service line is connected to the main.

Service Address \_\_\_\_\_ Lot # \_\_\_\_\_ City \_\_\_\_\_ Zip \_\_\_\_\_

**BILLING INFORMATION: (PLEASE PRINT CLEARLY)**

Customers Name: \_\_\_\_\_ Tel # \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_

Mailing Address: \_\_\_\_\_ City \_\_\_\_\_ ST \_\_\_\_\_ Zip Code \_\_\_\_\_

Authorized Agent Signature: \_\_\_\_\_ Owner \_\_\_\_\_ Gen Contractor \_\_\_\_\_

Date: \_\_\_\_\_ Tel # \_\_\_\_\_ (\_\_\_\_) \_\_\_\_\_ Address \_\_\_\_\_

**IW MORGAN USE ONLY:**

Meter Data: \_\_\_\_\_ Mk \_\_\_\_\_ Sz \_\_\_\_\_ Number \_\_\_\_\_ Mtr Rdg \_\_\_\_\_ T-ON \_\_\_\_\_ LOSW \_\_\_\_\_ Date/Svcn \_\_\_\_\_

8	7	6	5
9			4
0	1	2	3

## APPLICATION INSTRUCTIONS IW Morgan Water

An application must provide complete information before a permit can be approved. If this cannot be done on the face of the application, furnish sketch showing service arrangement with reference to buildings, lots and streets.

Information requested must be completely filled out when application is received or tap will be refused.

Written application and approval from the company must be obtained **BEFORE** any **installation or alteration of water service line is started**.

Phone or verbal application may be made for service line repair or replacement only.

Separate written application must be filed for each new service line (domestic, fire, or irrigation). In a single project, provide a plot plan showing streets, lot numbers, and service arrangement. Service lines 1 ½" or larger require a set of blue prints.

Printed rules governing water service are available upon request. Plans for all industrial, large commercial and residential, and all unusual installations should have advance approval before permit is requested. Plumbers should assure themselves of all Department requirements before starting a job and the Department accepts no responsibility for the failure to do so.

All irrigation service lines, and fire lines 2" and larger, **MUST BE** inspected before the trench is backfilled. Prompt service on inspections and tap installations for each plumber is dependent upon each plumber having his job ready when promised, or giving advance notice when his job will not be ready as promised. Department approval will be indicated by a green tag and disapproved by a red tag, with explanation.

### OUTLINE OF DEPARTMENT REQUIREMENTS

1. All domestic service and fire line installations must conform to Environmental Management Board Title 320.
2. Plumbers will be held responsible for faulty workmanship, including improper backfilling of trenches.
3. No plumber shall break Department seal on meter without authority.
4. Installation of yard hydrants is prohibited unless approved by the Department.
5. All requests for new service must have a tract survey, legal description or lot number and subdivision name. Those requests to serve more than one (1) building must also include a site plan showing all buildings, meter installations and proposed service pipes.
6. No cross-connections shall be permitted which will allow water to flow between IW-Morgan Water supply and any other supply unless proper protection devices, approved by the Indiana Department of Environmental Management and inspected by the Department, are installed.
7. No interconnection or plumbing arrangement shall be permitted which will allow water or other solutions to be admitted or drawn into the distribution system of the Department, or into lines connected therewith which are used for the conveyance of potable water.
8. All stop boxes and meter pits must be left to finished grade. Boxes must be centered over the stop and be free of obstructions.
9. Connection spacers shall be removed immediately after a test. Unless Department authorization has been obtained, no plumber shall leave a curb stop turned on to a premises without a meter.
10. Any fluctuation in pressure caused by a customer, that creates problems for another customer, is the responsibility of the customer causing the problem.
11. Minimum size of service pipe shall be ¾-inch for domestic and irrigation service and 2-inch for fire lines.
12. Minimum cover for all underground pipe shall be 4 feet. In buildings without basements, riser pipes shall be at least 4 ½ feet from any outside wall, and exposed underfloor piping must be provided with frost protection.
13. Service pipes, unless otherwise approved, shall be run in a straight line without bends within the building lines and at a right angle to the main.
14. Service pipe shall not be installed in a sewer trench. Shelving is not allowed.
15. When a service line is connected, IW-Morgan will disconnect all unused existing service lines at the main as part of the job.
16. For 1 ½ inch and larger lines, the stop and box shall be within 3 feet of the main. Boxes shall be properly blocked up.
17. Meter connections in pits shall be set with their centerline 16 inches below the top of cover.
18. Multiple meters in pits must have the meter connections tagged with the correct service address. The Department will provide tags.